

From

The Head
Department of Microbiology
PAU, Ludhiana.

To

The Principal
S.M.M.B. Memorial School
Gaushala Nehar Wali, Badhni Kalan
Distt Moga

Memo. No. 1657

Dated: 20/05/22

Subject: Bacteriological quality of drinking water (IS-10500:1991. BIS New Delhi).

Reference is made to your letter No. SMMB/93/22 dated 17.05.2022 regarding sample of water for bacteriological analysis.

REPORT

S. No.	Source	Coliform organisms		Faecal Coliform / E. coli Detected / Not detected
		Present/ Absent	Most Probable Number index (<10/100ml)	
01	Water sample	Absent	--	Not Detected

INFERENCE

Bacteriologically safe :- 01

Bacteriologically not safe :- nil

Amey
Technician
Water Testing Lab
Department of Microbiology
PAU, Ludhiana

[Signature]
Incharge
Water Testing Lab
Department of Microbiology
PAU, Ludhiana

NOTE: This result relates to the sample provided to us and laboratory is not responsible for drawing/collecting of samples. The contents of this report are meant for your guidance and should not be used for Advertisement, Evidence and Litigation. This test document shall not be reproduced without the permission of the University.

[Signature]
Head
Department of Microbiology